The Korean Activities of Oxy-Fuel Combustion

Youngju Kim, Sangil Seo, Jongsoo Kim

2nd Oxyfuel Combustion Conference Capricorn Resort, Yeppoon, Queensland, Australia 12th - 16th September 2011



CO₂





Contents

The Korean activities of Oxy-Fuel Combustion **Project** Outline

What We Have Done

What We Will Do







OXY-FUEL COMBUSTION R&D ORGANIZATION

1. Project Outline

Project Outline



Tentative Demo. Site (Youngdong TPP)

Plant 125MWe output STEAM Boiler Single-drum type radiant heat type Operation 1973 start Boiler : BHK Maker T/G : Hitachi REHEATER 0속초 Flow rate : 420t/h 韓国 Burners Main Temp. : 541deg-C Young Dong #1 ECONOMISER steam Pressure : 12.85MPa n 안동 대전이 Burner Circular type x 16 전주 type Bent type x 12 포함 Butne ●물산 광주 Tube type × 6 Mill 부산 (Standby x 1) type AIR HEATER Fuel Anthracite(FR*=14) 福岡 제준 Efficiency 36% 200 km 100 マイル * Fuel Ratio= Fixed Carbon/Volatile

IR ODÇƏN 🌕

DOOSAN



KIMM



Project Outline

Organization



Scope of Basic Design



2. What We Have Done

Feasibility Study Result (Boiler)

| Feasibility Cases | | | | |
|-------------------------------------|--|---|----------|------------|
| | Case 1 | Case 2 | Case 3-1 | Case 3-2 |
| | Retrofit | Retrofit | Retrofit | Brownfield |
| Boiler | Existing Downshot | Existing Downshot New Boiler | | v Boiler |
| Firing System | Downshot-Fired Circular Burners | Wall-Fired Circular Burners & New Windbox | | |
| Mill & PF Ducting | | Vertical Mill & New PF Piping, New PAF | | |
| Boiler Plant Layout | Maximum use of boiler New PAH & refurbished | r / boiler island components & layout New | | |
| Boilerhouse Primary Steelwork | | Existing New | | |

The Retrofit Case was selected to apply for verified Oxyfuel technology maximizing use of exiting boiler components & layout







| Feasibility Study | | Foosibility Study | | ibility Study | | Emissions | | | Capital | Total Expected | |
|-------------------|--------------------|-------------------|---------------------------------|-----------------------|----------------|--|------------------------------|--------|--------------------|-------------------|--|
| | T easibility Study | | Capacity ¹⁾ (t/h) | Efficiency (% GCV) | NOx (mg/MJ) | SOx (mg/MJ) | Dust (g/Nm ³) | (MUSD) | Period (months) | | |
| | Case 0 | Air- firing | 372 t/h | 82.0 % | tbc | 305 | 19.4 | - | - | | |
| | | Air- firing | 372 t/h | 83.3 % | Approx 120 | 340 | 2.9 | 27.0 | 26 | | |
| | Case I | Oxy- firing | 297 t/h | 86.9% | Approx 60 | 650 ²⁾ 120 ³⁾ | 3.7 | 27.0 | 20 | | |
| | | Air- firing | 372 t/h | 83.4 % | 90 | 340 | 2.9 | 07.7 | 20 | | |
| | Case 2 | Oxy- firing | 297 t/h | 87.1 % | 45 | 650 ²⁾ 120 ³⁾ | 3.7 | 21.1 | 20 | | |
| | Case 3-1 | Air- firing | 372 t/h | 83.6 % | 90 | 340 | 2.9 | 77.4 | 36 | | |
| | (3-2) | Oxy- firing | 297 t/h | 87.3 % | 45 | 650 ²⁾ 120 ³⁾ | 3.7 | (87.2) | (44) | | |

Notes :

1) Boiler Capacity was considered based on 372 t/h equivalent to 125 MWe gross for Air Firing and 297 t/h equivalent to 100 MWe gross for Oxy firing condition.

2) Uncontrolled SOx

3) In-furnace De-SOx (as proposed by KIMM)

4) Capital Cost was estimated as a results of Feasibility Study and is not guaranteed.









Thermal Performance Modeling & Prediction



 Boiler plant designed for air-firing can operate under oxyfuel firing conditions, without significant

heating surface pressure part modifications

 Low utilisation of lower furnace leading to high SH spray demand & high carbon-in-ash (short residence times).

Furnace

- Radiant heat transfer dominates
- Radiant heat transfer dominated by particulate material
- Impact of non-luminous gases radiation (CO2, H2O) small compared to particles
- Impact of oxyfuel compared to air is therefore expected to be small Convective pass
- Heat transfer based on gas properties, velocities
- Radiation has diminishing importance
- Performance is predictable using conventional design rules
- Minimal thermal impact of oxyfuel verified by pilot scale testing











Mechanical Design



| Retrofitted Boiler : WALL FIRED | | | |
|----------------------------------|---|--|--|
| Detailed Review:- | (to accommodate new burner loads) | | |
| Sling Tubes* | New, Rows 'A' & 'D' material upgrade | | |
| Furnace Wall Tubes 🧿 | No strength mods other than redundant tubeset replacement | | |
| Framing & 3 Attachments | New replacement 'hot' buck stay at one level | | |
| New Scope:- | | | |
| Burner Windbox | New | | |
| Burners & Burner 5 Openings | New OxyCoal™ Burner | | |
| Arch Pressure Parts 6 | New (ribbed bore tube or alternative tube) | | |
| Seal Casing | New | | |
| Overturning Posts & Buckstays | New (or strengthened) | | |
| Pressure Part Attachments | New | | |
| Supports* | New, Row 'B' sling rod material upgrade | | |

*Sling row definition - Refer Drg No.: KU1-122-601 Boiler Loading Plan









Conceptual GA



Environment Control System

What We Have Done



Environment Control System

1) Design Condition

| | Туре | Specification | Remarks |
|-------------|-----------------------------|--|---------------------|
| De-SOx | In-Furnace De-Sox(Dry Type) | limestone, 1t/hr, dry flue gas spray | New Build |
| Dry EP | Dry, Full Sealed | 510,000m3/hr, Temp. 210°C, Eff. 99.96% | New Build |
| FGC | Spray | 200,000m3/hr, Temp.120°C/30°C | Incl. cooling tower |
| Wet EP | Water Film | 200,000m3/hr, Temp.30°C, Eff. 95% | New Build |
| FGD | Wet Type FGD | 200,000m3/hr, Temp. 30°C, Eff. 98% | Reuse |
| Aux. filter | Filter | 10,000m3/hr, Temp. 30°C, Eff. 95% | New Build |

| 2) Capital Cos | t | | (MUSD) |
|----------------|---------|--------|--------|
| | CASE 1 | CASE 2 | CASE 3 |
| De-SOx | 1.5 | N/A | 1.5 |
| Dry EP | 5.0 | 5.0 | 5.0 |
| FGC | 1.2 | 1.2 | 1.2 |
| Wet EP | 2.0 | N/A | N/A |
| FGD | N/A | 5.0 | 5.0 |
| Aux. filter | N/A | 0.3 | 0.3 |
| Total | 9.7 | 11.5 | 13.0 |
| | ······· | | |









ASU & CPU

| | Basic Design Conditions for ASU | |
|----------------------------|--|-------------------------------|
| ASU Type | ASU Type Double Column | |
| O2 Purity | O2 Purity 95% | |
| Oxy mode | GO2 Producing, 20,000 Nm3/h LO2 Back-up, 40,000 Nm3/h | 1/3 Vs Full Load Demand |
| Air Mode | 20,000 Nm3/h | LO2 |
| Capacity of LO2 Tank | Capacity of 8,000 m3 | |
| Time for LO2 production | 11 ~ 12 days | For During Air Mode |



| | Basic Design Conditions for CPU | |
|-----------|---------------------------------|--------------------------------|
| CPU Type | Cryogenic | |
| Capacity | 10% Vs Full Load Demand | |
| CO2 Phase | GCO2, LCO2 | Depend on Operation Mode |



Process Diagram of Oxy-PC Power Plant

What We Have Done



Arrangement Plan of Main Facilities

What We Have Done



순산소연소연구단 **OXY-FUEL COMBUSTION R&D ORGANIZATION**

General Arrangement

What We Have Done

Boiler Island

ASU & CPU



Schematic Diagram of Test Bed



- > Oxy-PC Test Bed 100kg/hr(Coal),(0.7MWth)
- > Dual Mode Operation (Air & Oxy Mode)





KIMN



Test Bed – Combustion System



Test Bed - Environment Control System

What We Have Done



Developing of Dynamic Engineering Simulator

What We Have Done



Developing of Dynamic Engineering Simulator



Phase 1) YEONGDONG Unit 1 Engineering Simulator

Developing YEONGDONG Unit 1

Engineering Simulator

- Performance Verification of YEONGDONG
 - Unit 1 Engineering Simulator

Phase 2) Oxy-PC Dynamic Engineering Simulator

- Modifying YEONGDONG Unit 1 Engineering Simulator to Oxy-PC Dynamic Engineering Simulator
- Developing Boiler and Air/Gas System Model for Oxy-PC Dynamic Engineering Simulator
- Developing ASU and CPU System Model
- Verifying Boiler and Air/Gas System Control Logic

승산소연소연구단

OXY-FUEL COMBUSTION

R&D ORGANIZATION



Developing of Dynamic Engineering Simulator

What We Have Done



Developing of Process Analysis Tool

SteamGen Expert Plus ess Simulation Program m **************** -Multizone Furnace Module Dialog ? Solid Fuel Dialog Middleson-Fassie Feralt Disks Furnace l Init m Units... Name Mass Fraction of Solid Zone 15 26 0.0 Name Depth (X) Zone 14 27.8 0.537829 Height [Y] unGen Experi Nelbaren Mass Flow 38.55 Zone 13 ton/h Zone 12 Zone 11 Zone 10 Zone 9 Width (Z) 12.8 0.0378753 feat Loss Temperature 5800 Avra (M) 17295.6 HHV kcal/kg Point 1 (X) 11011 0.4319021 0.55 Total Heat Long 4.79E+01 1000 1010 Zone Zone Zone Zone Zone Zone Zone Zone 0.143926 Point 2 (X) 41 Heat Loss To Exit Heat Loss To Enclosure Wall Heat Loss To SH 1453.28 -627 1545.16 0.358754_0.14 LHV 5511.31 kcal/kg SE+0 23E+00 51E+00 0.355483 0.33 0.432797 0.35 Point 3 (Y) 3.8 0.00757506 Heat of Formation 499.801 Heat Loss To Waterwall Stream 1545 68 0.439122 0.14 kcal/kg 13E+08 395+07 19.8 1432 65 1717 65 1773 21 1773 21 0.334045 0.34 0.334045 0.34 0.334037 0.34 0.334037 0.34 0.334137 0.34 Point 4 (Y) leart Loss To Water Str ART 1 E 64E+03 595+07 740-+07 0.08 0.678242 kcal/kg Point 5 (X) Sensible Heat 377+07 Point 5 (Y) 797.407 1113 64 0.4-0500 0.14 0.4-7050 0.14 0.0265127 Ash. 499.122 1115 01 Total Enthaloy kcal/ko 12 No. of Burner Zones 0.166282 Flue Gas Exit Moist. Heat Capacity 1544.56 J/kaK No. of Nose Zones Rear Wall Side C Top of Furnace No. of Upper Zones Sum + Composition Basis Specify For Each Zone Total No. of Zones LUNC Volatile 0.4 Top of Zone (Y) ● Ast'd ○ Dry ○ Daf hopper) 🔥 Number of Cells In X 20 Zone: 2 (burner) Zone: 3 (burner) Number of Cells In Y 49 Zone: 4 (burner) Normalize Number of Cells Number of Cells In Z 20 Zone: 5 (burner) Zone: 6 (burner) Use Dulong's Update Y 4 Total Number of Cells 19600 Continue Set SH Set Walls Export Grid Cancel Cancel OK KEPRI Set PSD OK Set Streams. View Results.

26







OXY-FUEL COMBUSTION R&D ORGANIZATION

Developing of Process Analysis Tool

What We Have Done



3. What We Will Do

KOCRO Plan



Total Capital Investment : 130M USD

Cost Share

- Power Company : KEPCO, KOSEP
- Private Sector : Doosan, Daesung, KC Cottrell
- Korean Government

Preliminary Feasibility Study

- Every public project with over 50M USD MUST pass the preliminary feasibility study by the Ministry of Treasury.
- We will enter the 2012 PFS to get the 2013 budget allocation fr om the National Assembly









OXY-FUEL COMBUSTION

R&D ORGANIZATION

Dual Combustion Operation

- Expect to have 100day/year Oxy-Fuel Mode Operation
- Minimum 3 years operation
- Can be extended if additional needs (testing new technologies) arise

Operation Cost

- Need to compensate the loss of revenue by Oxy-Fuel Operation
- 10M USD per year

Potential Compensation Methods

- RPS
- CTS
- Adjustment of Power Whole Sale Price









Technical Front : Sailing Smooth

- Ready to complete the Demonstration Plant Construction by 2015
- Dual Combustion Mode Allows Us A Very Flexible Operation
 - Test Different Technological Options
 - Can Go Back to Air-Firing Mode until the Technical Problems are Fixed if they arise
- There is a Window of Opportunity to Deploy Brand-New Commercial Scale Oxy-Fuel Power Plant in Korea After 2020

Political Front : Foggy

- Much of the Driving Force for Global Climate Change Mitigation Has Been Evaporated
- We Do Not Know Whether the Korean Government Is Willing to Move Ahead in This Circumstance.

Storage

- Lagging behind the Capture Technology Development
- Yet to Hear from the National Geological Institute and Korea National Oil Corporation about the Commercial Scale Off-Shore CO2 Storage Sites













