



1st Post Combustion Capture Conference

Economic benefit of Lean Vapor Compression in a carbon capture plant

Bergsma E.J.^{*}, Sanchez-Fernandez E., Goetheer, E.L.V.

TNO separation Technology, Leeghwaterstraat 46, 2628 CA Delft, The Netherlands

Keywords: carbon capture, MEA, lean vapor compression, LVC, economics

1. Introduction

Energy optimization is crucial for the lowering of operational cost for post combustion capture. Next to solvent optimization, process optimization is of equal importance. An interesting aspect can be the use of lean vapor compression (LVC). This comprises flashing of the bottom stream of a stripper and recycling the resulting vapor after compression to the bottom stage of the stripper. LVC has proven to be technically feasible in the European project CESAR. In this study a detailed economic assessment for the capital and operational expenditure is made for a demo-scale MEA capture plant of 180 ton CO₂ per hour.

2. Approach

A standard CO₂ capture plant based on 30wt% MEA was modelled in Aspen+. This model was verified based on the comparison with experimental data from the Esbjerg pilot plant. This modelled process was scaled up to a 180 ton/hr capture plant which was connected to a coal-fired power plant. Two cases were considered:

1. Design of the capture plant with LVC to arrive at minimal investment cost.
2. Using LVC as an add-on to an already designed capture plant.

At the process settings listed in Table 1, the pressure in the LVC flash vessel was varied from 1 to 1.8 bara.

Table 1: Settings used in MEA capture process.

Capture percentage	90	Flue gas	
MEA concentration [wt%]	30	CO ₂ [mol%]	0.137
Stripper pressure (drop) [bara]	1.8 (0.1)	H ₂ O [mol%]	0.119
CO ₂ recovery to stripper bottom	0.57	T/P [C]/[bara]	40 / 1.1
T lean absorber feed [°C]	40	Flow [kg/s]	254

For each pressure, the net present value of the gain and cost of LVC were calculated using the parameters in Table 2. The following gains/costs were considered:

- Energy cost: by application of LVC, the energy requirement for boil-up in the stripper is divided between the reboiler and the LVC compressor. In order to add the electrical energy to the thermal energy, the electrical energy was divided by 0.25. This is the reduction in power-output of the power plant per megawatt of reboiler energy generally seen in carbon capture calculations.
- Equipment cost: quotes were made for the main equipment of the capture process. In order to calculate equipment prices for each LVC case the quotes were scaled using the appropriate price functions for each piece of equipment.

Table 2: Parameters used to calculate the NPV of the yearly costs and gains.

Interest percentage	8%	Depreciation	Years
Lang factor (installed/purchased)	4	Compressor	10 (lowered for maintenance + revision)
Electricity [€/MWh]	50	Flash vessel	25
Time period (years)	25	Heat exchangers	20 (lowered for maintenance)

3. Results

The calculated thermal duties and the difference in equipment cost compared to a plant without LVC are listed in Table 3. The operational and capital cost of the reboiler, condenser, LVC compressor, and LVC flash have been calculated. The rest of the equipment is assumed not to be significantly affected by the LVC. For case 2, only the cost of the LVC compressor and flash are considered, as they are the add-on to the existing process. As the pressure in the LVC flash vessel lowers, more vapor is formed and, with the vapor, more heat is pumped into the stripper bottom by LVC, hence the reboiler duty lowers. It can be seen that the electric duty of the LVC compressor rises exponentially with lowering flash pressure.

In case 1 the cost of the lean-rich heat exchanger and the condenser lower with decreasing flash pressure. This results in over-all lower investment cost for case 1. This is offset by the slightly higher energy gain in case 2.

The NPV of the yearly gains and cost over 25 year is given in Table3. This shows that for both cases the highest benefit of LVC can be attained at a flash pressure of~1.2 bara. Moreover, the gain over 25 years is the same for both cases. Case 2 will yield the highest plant flexibility and is therefore the most favorable option.

Table 3: resulting duties and equipment cost for case 1 and 2. Left box: Case1, right box: case 2.

P _{LVC} bara	Reboiler duty MW _{th}	LVC duty MW _e	investment cost difference M€	NPV energy reduction M€	NPV total cost reduction M€	Reboiler duty MW _{th}	LVC duty MW _e	investment cost difference M€	NPV energy reduction M€	NPV total cost reduction M€
	1.8	172	0.0	0	0	0	172	0.0		0
1.4	158	0.8	-0.20	11.2	11.2	157	0.8		12.3	10.8
1.2	150	2.0	0.20	14.7	13.0	149	1.9		16.3	13.0
1	141	4.0	0.86	16.0	11.3	139	3.9		18.8	12.0

It can be concluded that LVC is an interesting option for lowering the cost of post combustion capture. It is to be expected that LVC will lead to improvement for other solvent systems. However, this needs to be evaluated case by case.

* Corresponding author. Tel.: +31 31 (0) 8886 62156; fax: +31 (0)15 269 2111.

E-mail address: bertus.bergsma@tno.nl.